


# IMPACTS OF FERC ORDER 881 ON UTILITIES

## TACOMA POWER'S PATH ON AMBIENT ADJUSTED RATING & FERC ORDER 881 COMPLIANCE

Presented by Travis Filleau, PE  
Tacoma Power, System Planning Engineer

# ABOUT TACOMA POWER

- Tacoma Power is a publicly owned electrical utility serving the greater Tacoma area.
- Serve around 200,000 customers.
- Tacoma Power is a vertically integrated utility.
  - GO, GOP, TO, TOP, TP, DP, BA ...
- Own and operate transmission system of 230kV and 115kV.
  - 308 miles of 115kV
  - 44 miles of 230kV




# TRANSMISSION LINE RATINGS

## What are they?

Transmission line ratings define the amount of electrical current a transmission line can safely carry under specific conditions without violating safety, reliability or equipment limits.

## Why do we need them?

- As conductor temperature increases, the conductor expands causing increased sag.
- If a conductor gets beyond a certain temperature, it could cause the conductor to sag beyond allowable clearances, ratings.
- There is a known temperature limit for the conductor.
- With some assumed external variables, the rating provides the amount of current that can flow before the allowable conductor temperature is exceeded.



# TRANSMISSION LINE RATINGS


## What factors play into a transmission line rating?

- Transmission line ratings are essentially a heat balance problem.
  - Heat in = Heat out, while at the maximum allowable conductor temperature.
- IEEE 738 – Calculating the Current-Temperature Relationship of Bare Overhead Conductors

## Components

- Solar Heat Gain ( $q_s$ )
- Convective Cooling ( $q_c$ )
- Radiative Cooling ( $q_r$ )
- Joule Heating ( $I^2 R$ )

$$I = \sqrt{\frac{q_c + q_r - q_s}{R(T_{\text{avg}})}}$$



# RATING PARAMETERS

## Environmental Conditions

- **Ambient Temperature**
  - Higher Temperatures = Less Cooling
- **Wind Speed & Direction**
  - Higher wind speeds = More convective cooling
- **Solar Radiation**
  - Midday, Clear Sky = More Heating
    - Time of year, Time of day, Latitude, Elevation, Atmosphere Pollution



## Conductor Properties

- **Conductor Temperature**
- **Diameter**
- **Emissivity**
  - How well it radiates heat.
- **Absorptivity**
  - How well it absorbs solar heat.
- **Resistance**
  - Heating is proportional to  $I^2 R$



**All these parameters effect the ampacity calculation.**

# TYPES OF TRANSMISSION LINE RATINGS

## Static

- Fixed rating used year-round.
- Often highly over conservative.
- Was the industry normal for most of history.

## Seasonal

- Ratings change based on season.
- Different ambient temperature assumptions for each season.
- Had been widely used today by many utilities.

## Ambient Adjusted Ratings (AAR)

- Ratings change in real-time based on measured ambient temperature.
- Ratings vary based on different ambient temperature windows.
- Adoption of AAR more becoming more prevalent. FERC 881 driven.

## Dynamic Line Ratings (DLR)

- Ratings change in real-time based on measured ambient temperature and other components.
  - Wind Speed & Direction
  - Solar Radiation
- Still early in the industry but likely to become more prevalent.



# HISTORY OF TACOMA POWER'S RATINGS

## Static

- Used static facility ratings prior to 2007.

## Seasonal

- Starting using seasonal ratings in 2007.
  - Different ambient temperature assumptions for Spring, Summer, Fall, Winter.
  - All other assumptions remained static.

## Ambient Adjusted Ratings

- In 2017, Tacoma Power implemented a version of Ambient Adjusted Ratings.
- Tracking towards a full FERC 881 compliance in 2026.

## Dynamic Line Ratings

- Tacoma Power is currently sponsoring a UW Seattle Capstone project to assess the feasibility of using DLR technologies.

# TACOMA POWER AAR'S

## Ambient Adjusted Ratings

- Tacoma Power uses seven different normal and emergency ratings based on ambient temperature.
- These ratings range from 0°C - 30°C (32°F - 86°F) in 5°C increments.
- All other variables are static.

## Methodology

- Our line engineering department provides the allowable operating temperature for a line segment.
  - LiDAR data used to determine operating temp.
- The allowable ampacity for the given operating temperature is determined for a conductor at each ambient temperature window.
  - Calculated per our Facility Rating Methodology.

# FACILITY RATING METHODOLOGY

Transmission conductor ratings are established based on IEEE 738 with the following assumptions.

| Parameter  | Assumption |                   |
|--|------------|-------------------|
|  | Normal     | Emergency         |
| Duration   | continuous | ≤30 minutes       |
| Conductor Surface Temperature                            | *          | *                 |
| Ambient Temperature                                      | **         | **                |
| Wind Speed   | 2 ft/sec   | 3 ft/sec          |
| Wind Angle (90 degrees = perpendicular)                  | 90 degrees | 90 degrees        |
| Emissivity of Conductor                                  | 0.5        | 0.5               |
| Absorptivity of Conductor                                | 0.5        | 0.5               |
| Solar Heating (on or off)                                | On         | On                |
| AC Resistance@25°C                                       | ***        | ***               |
| AC Resistance@75°C                                       | ***        | ***               |
| Elevation  | 200 ft     | 200 ft            |
| Time of Day  | 11:00 AM   | 11:00 AM          |
| Solar Day  | June 10    | June 10           |
| Latitude (Degrees - North positive)                      | 47         | 47                |
| Azimuth of Conductor (N-S=0, E-W=90 degrees)             | 90         | 90                |
| Type of Atmosphere (clear or industrial)                 | Clear      | Clear             |
| Pre-loading condition (initial current, I <sub>i</sub> ) | N/A        | 60% normal rating |

\* Conductor Surface Temperature is specific to each individual line  
 \*\* Ambient Temperature Assumptions are: 0°C for Winter, 20°C for Fall/Spring, and 30°C for Summer. When needed, the actual ambient temperature can be considered to determine the conductor ratings.  
 \*\*\* Resistance is specific to each individual conductor

## Takeaways

- Some assumptions considered conservative in nature.
- Lack of system constraints did not warrant additional review of assumptions.

# AAR IMPLEMENTATION

## How we calculate:

- Conductor type, operating temperature and rating assumptions are manually input into a program to determine the continuous and emergency ratings.
  - 14 conductor types, 3 operating temperatures and a handful of one-offs.
  - Roughly a 1000 manually calculated ratings... Do it once and done though! (Also done before my time)
- Ratings housed in an excel spreadsheet. This spreadsheet then determines the most limiting element for a defined Facility.
  - Transmission Line Section, Line Switch, Substation Bus, Substation Equipment.

## How we use:

### Real-time

- Temperature sensor at two of our substations.
  - Primary and Backup
- SCADA readings from sensor point back to a lookup table in EMS to determine which rating is in use.

### Next Day Study

- Ratings based on forecasted ambient temperature used in next-day studies.

10

# FERC ORDER 881

## Managing Transmission Line Ratings

- Goal is to enhance the efficiency of transmission service and improve transparency of transmission line ratings.
- The order requires transmission providers to implement ambient adjusted ratings on the transmission lines which they provide transmission service.

## Requirements of 881

- Transmission line ratings must reflect the actual ambient temperature.
- Ratings must be calculated for at least historical temperatures ranges with a +/- margin of 10°F.
- Ratings must be available for every 5°F change of temperature.
- Ratings account for daytime & nighttime solar heating changes.
- Entities provide forecasted ratings for every hour, extending 240 hours into the future.

# IMPACTS OF FERC ORDER 881

## How does this impact us?

Ratings must be available for every 5°F change of temperature ranging from historical high/low with a +/- margin of 10°F.

- All time high in Tacoma: 105°F in June 2021
- All time low in Tacoma: 5°F in November 1985
- Ratings must now extend from -5°F to 115°F.
- This would require 25 different continuous and emergency ratings compared to the 7 currently used.
  - How will the expanded range impact the ratings? And ultimately, system performance?

Ratings account for day/night solar heating changes.

- This would require an entire additional rating set, 50 total, with no solar heating assumptions.
  - How do we implement this in real-time operations?

Forecast ratings for every hour extending 240 hours. Updated hourly.

- No process currently in place.

# IDENTIFYING IMPACTS

## Where do we go from here?

- Need to determine the impacts of the expanded temperature windows.
  - Start by building the new rating set with the existing methodology.
    - One with solar assumptions and one without.
  - With these new rating sets, perform power flow analysis using more extreme ambient temperature assumptions.

## Step 1: Calculate New Ratings

- 60 different conductor type & operating temperature combinations.
- 25 different normal & emergency ratings for each conductor type/operating temp combo.
- Double that for night ratings with no solar component.

**After adding all that up, we just need to manually calculate 6000 new ratings...**

**Sounds like a great project for the Summer Intern!**



# INITIAL RESULTS

**Initial results indicated that at high ambient temperatures, system performance requirements could not be met.**

- More than 10 line sections exceeded continuous rating under N-0 conditions at 105°F.
  - Major lines at 400 and 500% of rating.
- N-1 scenarios intensify exceedances on previously limited sections.
  - Lines could exceed 600% of rating.

## Overview

- Ratings at higher ambient temperatures were significantly reduced.
- System had many lines with operating temperature of 49°C. These lines had ratings pushed to near zero when ambient temps reach above 100°F.



# INITIAL RESULTS

## Example

- Ambient Temp: 104°F
- Loading: Peak Summer Day

| Line Name    | Existing 30°C Rating (Amps) | Existing Methodology Rating (Amps) | Percent Reduction (%) |
|--------------|-----------------------------|------------------------------------|-----------------------|
| 115kV Line A | 271 (54MW)                  | 123 (24.MW)                        | 54.6                  |
| 115kV Line B | 236 (47MW)                  | 117 (23.3MW)                       | 50.4                  |
| 230kV Line A | 1198                        | 182                                | 84.8                  |
| 230kV Line B | 1198                        | 182                                | 84.8                  |

- Hourly average flows during peak Summer hours:
  - 230kV Line A: 326A
  - 230kV Line B: 401A

# POTENTIAL MEDIATIONS

**It was obvious from the results that action needed to be taken.**

- Identified some potential ways to mediate.

## LiDAR Assessment

- Another LiDAR study had just been performed on our transmission lines.
  - Performed in 2022. Analysis was on-going at this time.
- Hope was that the results would increase the operating temperature on many lines.
  - If not, provide most up-to-date limitations.

## Revised Methodology

- Assumptions in our ratings calculation could be adjusted to help improve ratings.
  - Wind Speed Assumptions
  - Solar Day
  - Time of Day

# LIDAR STUDY

## Previous LiDAR Data Process

- LIDAR data was being provided to us by 3<sup>rd</sup> party. Results were provided at random.
- Line Engineering would then periodically process the results, and report any updates as needed.
  - No insight into reasoning for given operating temperature.
  - Higher allowable operating temps may have not been provided if previously adequate.

## Revamped Process

- Streamlined Results
  - Discussed the importance of review.
  - Prioritized review of 49°C lines.
- More insight
  - Got access to information pertaining to results and operating temperature limitations.
  - Every degree for every line section.
- Call to action
  - Immediate Work Orders for small fixes such as pole tops, comms, etc.
  - Identified lines that necessitated larger fixes. Work Orders created.

# UPRATE IN ACTION

A backbone 230kV line had an operating temperature of 49°C. Per our analysis, It was imperative that an uprate occurred.

The culprit for the limited operating temperature....



Some additional tensioning of the line increased the operating temp to 67°C.



# UPRATE RESULTS

## Results

- Initially, 80-line sections with an operating temperature of 49°C.
- All have been increased to at least 57°C.
  - 60 of these lines have been increased to 100°C.
- Almost 200 out of 328 had an increase in operating temperature.
  - Average increase of 31°C.
  - Roughly 80% of increases due to updated LiDAR results and full scope of data.
- Roughly 40 Work Orders Completed.
  - \$500,000 in costs.

## Quick Compare

Rated Ampacity of 1272AAC at 35°C ambient temperature:

Operating Temperature of 49°C : 429A

Operating Temperature of 100°C : 1344A

# WIND SPEED ASSUMPTIONS

**One way to increase a conductor rating is to increase the assumed wind speed.**

- Wind Speed is one of the most impactful inputs for a line rating.

## Quick Compare:

Rated Ampacity of 1272AAC at 25°C ambient temperature and 100°C operating temperature:

Wind Speed of 2ft/s : 1450A

Wind Speed of 4ft/s : 1707A

**To justify any change to the existing methodology, we need to have data to back it up.**

- In 2022, intern performed an historical analysis of instantaneous wind speed versus ambient temperature.
  - Probabilistic Wind speed at temperature windows was analyzed using data back to 1950 from three local weather stations.

# WIND SPEED ASSUMPTIONS

*Table 3b. 0.05 quantile wind speeds (ft/s). (Normal Rating)*

|                                   | <b>72-77°F</b> | <b>77-82°F</b> | <b>82-87°F</b> | <b>87-92°F</b> | <b>92-97°F</b> | <b>97-102°F</b> |
|-----------------------------------|----------------|----------------|----------------|----------------|----------------|-----------------|
| <b>Combined stations</b>          | 2.92           | 3.57           | 3.92           | 4.34           | 4.28           | 4.58            |
| <b>Combined stations w/ noise</b> | 3.20           | 3.79           | 4.08           | 4.41           | 4.25           | 4.31            |

*Table 4b. 0.1 quantile wind speeds (ft/s). (Emergency Rating)*

|                                   | <b>72-77°F</b> | <b>77-82°F</b> | <b>82-87°F</b> | <b>87-92°F</b> | <b>92-97°F</b> | <b>97-102°F</b> |
|-----------------------------------|----------------|----------------|----------------|----------------|----------------|-----------------|
| <b>Combined stations</b>          | 4.15           | 4.89           | 5.28           | 5.76           | 5.70           | 6.04            |
| <b>Combined stations w/ noise</b> | 4.47           | 5.13           | 5.47           | 5.91           | 5.77           | 6.71            |

*Table 5b. Number of samples used for wind speed quantiles.*

|                          | <b>72-77°F</b> | <b>77-82°F</b> | <b>82-87°F</b> | <b>87-92°F</b> | <b>92-97°F</b> | <b>97-102°F</b> |
|--------------------------|----------------|----------------|----------------|----------------|----------------|-----------------|
| <b>Combined stations</b> | 67836          | 28127          | 11358          | 3246           | 1049           | 145             |

# ASSUMED WIND SPEED

| <i>Ambient Air Temp (F)</i>                   | <i>Wind Speed Assumptions</i> |                           |
|---|-------------------------------|---------------------------|
|   | <i>Normal (ft/sec)</i>        | <i>Emergency (ft/sec)</i> |
| $\leq 70^{\circ}$                             | 2                             | 3                         |
| $70^{\circ} < \text{ and } \leq 75^{\circ}$   | 2.18                          | 3.28                      |
| $75^{\circ} < \text{ and } \leq 80^{\circ}$   | 2.92                          | 4.15                      |
| $80^{\circ} < \text{ and } \leq 85^{\circ}$   | 3.57                          | 4.89                      |
| $85^{\circ} < \text{ and } \leq 90^{\circ}$   | 3.92                          | 5.28                      |
| $90^{\circ} < \text{ and } \leq 95^{\circ}$   | 4.28                          | 5.70                      |
| $95^{\circ} < \text{ and } \leq 100^{\circ}$  | 4.28                          | 5.70                      |
| $100^{\circ} < \text{ and } \leq 105^{\circ}$ | 4.58                          | 6.04                      |
| $105^{\circ} < \text{ and } \leq 110^{\circ}$ | 4.58                          | 6.04                      |
| $110^{\circ} <$                               | 4.58                          | 6.04                      |

# DAY & TIME ASSUMPTIONS

## Solar Day

- Existing methodology assumes June 10<sup>th</sup> for all ratings. This is the most limiting day of year.
- Additional capacity can arise from using less conservative day.
  - Using actual day of each year would require a completely new rating set for each day.
  - For a seasonal use, the most limiting day for the season would need to be used.
  - Overall, the theoretical gain is small. Not worth the effort.

## Time of Day

- Existing methodology assumes 11:00am for all ratings.
- Additional capacity can arise from using less conservative time of day.
  - Again, using actual time would require different data sets.
  - The theoretical gain is small.
- System is most constrained during peak hours. Analysis is done assuming peak scenarios.
  - Our ratings should reflect the time of day the system is most constrained.
  - This was justification to adjust the time of day to 8:00am/4:00pm.

# UPDATED RATING RESULTS

## To summarize mitigation efforts...

- Work with Line Engineering to prioritize review of LiDAR data and uprate of limited lines.
- Revised Facility Rating Methodology assumptions backed by engineering judgement and historical evidence.
  - Higher wind speed assumptions at high ambient temperatures.
  - Time of Day changed to capture peak load hours.

**Now, the moment of truth...**

**Would these changes be enough to meet our system performance requirements at higher ambient temperatures?**

# UPDATED RATING RESULTS

Finished with no violations, custom monitor violations, unsolveable or aborted contingencies. Initial state restored.

**No SOL violations at N-0 or N-1 scenarios! System Performance requirements were met.**

- Even at assumed ambient temperatures of 115°F.
- 268/328-line sections saw an increased ampacity at 115°F compared to the previous 86°F ratings.

**Not quite finished...**

- Satisfied with the outcome of the new rating set, Facility Rating Methodology.
- However, still some remaining challenges.

# IMPACTS TO EMS

## New EMS Requirements

Due to these updates, EMS system required:

- Look up table with 25 different continuous and emergency ratings.
- Additional look up table for night ratings.
- New process to determine when Day/Night rating were in effect.

## Outcome

- Started with collaboration between EMS group.
- Modified existing setup to accommodate additional ratings.
- Created an additional parameter to select day or night ratings.
  - Lookup table of sunset and sunrise times for each day.

# ADDITIONAL FERC 881 IMPACTS

## FERC Order No. 881 requires ISO's/RTO's to utilize AAR ratings in their:

- Real time congestion management process.
- Real time and look ahead market commitment process and look ahead reliability studies.
- Evaluation and curtailment of near term (10 days or less) transmission service.

## RCWEST/CAISO

- To receive real time ambient adjusted ratings from TO's for use in their real time reliability monitoring process.
  - Went live in July 2025. RCWEST receives are real-time AAR's via ICCP.
- To receive forecasted ratings extending 240 hours for every hour to be used in market applications and look ahead reliability applications.
  - Still in development. Targeted functionality by Q3 2026. Required to begin submission before October, 2027.

# 240-HOUR LOOK AHEAD RATINGS

**CAISO is using a OATI tool called WebLineR to collect and implement the forecasted facility ratings.**

- WEIM Entities are required to submit their forecasted AAR's to this tool.
- Ratings must be submitted every hour extending 240 hours.

**Tacoma Power has consulted with PCI to use their Line Rating Management System (LRMS) Software.**

- Tacoma Power provides the facilities and ratings tables.
- The LRMS uses forecasted weather data to determine the assumed rating for each facility for every hour, extending 240 hours.
- The LRMS uses API to submit the ratings to the WebLineR every hour.
- LRMS will also update the TTC on OASIS for the next 240 hours.

# CURRENT STANDING & NEXT STEPS

## Current Standing

- Updated Facility Rating Methodology and Ratings.
- Completed development & testing of new EMS functionality.

## Next Steps

- Get leadership approval on changes to methodology and implementation of new ambient adjusted ratings.
- Complete all development, review & testing of new ratings and impacted workflows.
- Develop a cutover procedure/timeline in coordination Operations.
- Integrate the PCI tool in Q4 of 2026 (No later than October 15, 2027).

# Questions and Feedback?

*Thank  
you!*

# Sources

[https://www.google.com/imgres?q=overhead%20conductor%20properties&imgurl=https%3A%2F%2Fkoala.sh%2Fapi%2Fimage%2Fv2-17Y3PE-LAHJP.JPG%3Fwidth%3D1536%26height%3D1024%26dream&imgrefurl=https%3A%2F%2Ftitanwnc.com%2F2026%2F02%2FDifferent-materials-for-electrical-wire%2F%3Fsrsltid%3DAFMBOORJMSANQ9UULWNKPGQDBRVIMQNBSSDZ8TA9QT17YA99TKUM2S&docid=1XLRD5H8ESXSXM&tbid=KHQ\\_MBMCA9UBM&vet=12AHUKEWJZRVRUS8QTAXWGIJQHUVJNVWQNPaoegQIEXAB..I&W=1536&H=1024&HCB=2&VED=2AHUKEWJZRVRUS8QTAXWGIJQHUVJNVWQNPaoegQIEXAB](https://www.google.com/imgres?q=overhead%20conductor%20properties&imgurl=https%3A%2F%2Fkoala.sh%2Fapi%2Fimage%2Fv2-17Y3PE-LAHJP.JPG%3Fwidth%3D1536%26height%3D1024%26dream&imgrefurl=https%3A%2F%2Ftitanwnc.com%2F2026%2F02%2FDifferent-materials-for-electrical-wire%2F%3Fsrsltid%3DAFMBOORJMSANQ9UULWNKPGQDBRVIMQNBSSDZ8TA9QT17YA99TKUM2S&docid=1XLRD5H8ESXSXM&tbid=KHQ_MBMCA9UBM&vet=12AHUKEWJZRVRUS8QTAXWGIJQHUVJNVWQNPaoegQIEXAB..I&W=1536&H=1024&HCB=2&VED=2AHUKEWJZRVRUS8QTAXWGIJQHUVJNVWQNPaoegQIEXAB)

[https://www.google.com/imgres?q=sun%20clip%20art&imgurl=https%3A%2F%2Fthumbs.dreamstime.com%2FB%2FSun-clouds-clip-art-illustration-vector-isolated-sun-clouds-clip-art-illustration-vector-isolated-white-background-200578469.JPG&imgrefurl=https%3A%2F%2Fwww.dreamstime.com%2Fillustration%2FSun-clouds-clip-art-illustration-vector-isolated.html&docid=zv\\_geysdhp6kBM&tbid=LP8I3353WVWHQM&vet=12AHUKEWIZG5K8TMQTAXWVJTQIHSGCJFEQNPaoegQIBRAB..I&W=800&H=611&HCB=2&VED=2AHUKEWIZG5K8TMQTAXWVJTQIHSGCJFEQNPaoegQIBRAB](https://www.google.com/imgres?q=sun%20clip%20art&imgurl=https%3A%2F%2Fthumbs.dreamstime.com%2FB%2FSun-clouds-clip-art-illustration-vector-isolated-sun-clouds-clip-art-illustration-vector-isolated-white-background-200578469.JPG&imgrefurl=https%3A%2F%2Fwww.dreamstime.com%2Fillustration%2FSun-clouds-clip-art-illustration-vector-isolated.html&docid=zv_geysdhp6kBM&tbid=LP8I3353WVWHQM&vet=12AHUKEWIZG5K8TMQTAXWVJTQIHSGCJFEQNPaoegQIBRAB..I&W=800&H=611&HCB=2&VED=2AHUKEWIZG5K8TMQTAXWVJTQIHSGCJFEQNPaoegQIBRAB)

[https://www.google.com/imgres?q=transmission%20line%20ratings&imgurl=https%3A%2F%2Fwww.wsp.com%2F-%2FMEDIA%2Finsights%2FUS%2FUNlocking-grid-capacity%2Fimg-unlocking-grid-capacity-evolution-of-line-ratings.JPG%3FLA%3DEN-US%26H%3D300%26W%3D915%26HASH%3DE77E74253D557F80C21CCA75CD489333&imgrefurl=https%3A%2F%2Fwww.wsp.com%2FEN-US%2Finsights%2F2025-from-static-to-dynamic-unlocking-grid-capacity&docid=QQY7JK-FSXJVTM&tbid=0VDK8MFP41TFM&vet=12AHUKEWISZ\\_BSTCQTAXVOJZQIHD\\_IH3GQNPaoegQIFXAB..I&W=915&H=300&HCB=2&VED=2AHUKEWISZ\\_BSTCQTAXVOJZQIHD\\_IH3GQNPaoegQIFXAB](https://www.google.com/imgres?q=transmission%20line%20ratings&imgurl=https%3A%2F%2Fwww.wsp.com%2F-%2FMEDIA%2Finsights%2FUS%2FUNlocking-grid-capacity%2Fimg-unlocking-grid-capacity-evolution-of-line-ratings.JPG%3FLA%3DEN-US%26H%3D300%26W%3D915%26HASH%3DE77E74253D557F80C21CCA75CD489333&imgrefurl=https%3A%2F%2Fwww.wsp.com%2FEN-US%2Finsights%2F2025-from-static-to-dynamic-unlocking-grid-capacity&docid=QQY7JK-FSXJVTM&tbid=0VDK8MFP41TFM&vet=12AHUKEWISZ_BSTCQTAXVOJZQIHD_IH3GQNPaoegQIFXAB..I&W=915&H=300&HCB=2&VED=2AHUKEWISZ_BSTCQTAXVOJZQIHD_IH3GQNPaoegQIFXAB)

[https://www.google.com/imgres?q=transmission%20line%20ratings&imgurl=https%3A%2F%2Ftva-azr-eastus-cdn-ep-tvawcm-prd.azureedge.net%2FCDN-TVawCMA%2Fimages%2Fdefault-source%2Ftransmission-towers%2Flinesag.JPG%3FsvrSN%3DF01FBD6E\\_1&imgrefurl=https%3A%2F%2Ftva.com%2Fthe-powerhouse%2Fstories%2FWintertime-transmission-bag-the-sag&docid=\\_FXLD1EPLKVKKM&tbid=CEX6OLHGJGE-2M&vet=12AHUKEWJAZN78TCQTAXWFJQIHT6RBQGQNPaoegQIMHAA..I&W=600&H=400&HCB=2&VED=2AHUKEWJAZN78TCQTAXWFJQIHT6RBQGQNPaoegQIMHAA](https://www.google.com/imgres?q=transmission%20line%20ratings&imgurl=https%3A%2F%2Ftva-azr-eastus-cdn-ep-tvawcm-prd.azureedge.net%2FCDN-TVawCMA%2Fimages%2Fdefault-source%2Ftransmission-towers%2Flinesag.JPG%3FsvrSN%3DF01FBD6E_1&imgrefurl=https%3A%2F%2Ftva.com%2Fthe-powerhouse%2Fstories%2FWintertime-transmission-bag-the-sag&docid=_FXLD1EPLKVKKM&tbid=CEX6OLHGJGE-2M&vet=12AHUKEWJAZN78TCQTAXWFJQIHT6RBQGQNPaoegQIMHAA..I&W=600&H=400&HCB=2&VED=2AHUKEWJAZN78TCQTAXWFJQIHT6RBQGQNPaoegQIMHAA)

[https://www.researchgate.net/figure/Thermal-balance-of-an-overhead-conductor-according-to-IEEE-738\\_Fig2\\_383770851](https://www.researchgate.net/figure/Thermal-balance-of-an-overhead-conductor-according-to-IEEE-738_Fig2_383770851)

[https://www.google.com/imgres?q=thank%20you&imgurl=https%3A%2F%2Fimg.freepik.com%2FFree-vector%2Fthank-you-lettering\\_1262-6963.JPG&imgrefurl=https%3A%2F%2Fwww.freepik.com%2FFree-photos-vectors%2Fthank-you&docid=TELRSLCHXVFSGM&tbid=KTN0IXBWHHWNM&vet=12AHUKEWJWYR6ZCQTAXVALTQIHfHRGZGQNPaoegQIHRAB..I&W=626&H=443&HCB=2&VED=2AHUKEWJWYR6ZCQTAXVALTQIHfHRGZGQNPaoegQIHRAB](https://www.google.com/imgres?q=thank%20you&imgurl=https%3A%2F%2Fimg.freepik.com%2FFree-vector%2Fthank-you-lettering_1262-6963.JPG&imgrefurl=https%3A%2F%2Fwww.freepik.com%2FFree-photos-vectors%2Fthank-you&docid=TELRSLCHXVFSGM&tbid=KTN0IXBWHHWNM&vet=12AHUKEWJWYR6ZCQTAXVALTQIHfHRGZGQNPaoegQIHRAB..I&W=626&H=443&HCB=2&VED=2AHUKEWJWYR6ZCQTAXVALTQIHfHRGZGQNPaoegQIHRAB)